

Northumbria Research Link

Citation: Underwood, Chris (2005) A fuzzy logic controller for temperature control of air handling plant. In: CSTB Matlab / Simulink Building and HVAC Simulation Workshop, 3-4 November 2005, Paris.

URL:

This version was downloaded from Northumbria Research Link:
<http://nrl.northumbria.ac.uk/id/eprint/3704/>

Northumbria University has developed Northumbria Research Link (NRL) to enable users to access the University's research output. Copyright © and moral rights for items on NRL are retained by the individual author(s) and/or other copyright owners. Single copies of full items can be reproduced, displayed or performed, and given to third parties in any format or medium for personal research or study, educational, or not-for-profit purposes without prior permission or charge, provided the authors, title and full bibliographic details are given, as well as a hyperlink and/or URL to the original metadata page. The content must not be changed in any way. Full items must not be sold commercially in any format or medium without formal permission of the copyright holder. The full policy is available online: <http://nrl.northumbria.ac.uk/policies.html>

This document may differ from the final, published version of the research and has been made available online in accordance with publisher policies. To read and/or cite from the published version of the research, please visit the publisher's website (a subscription may be required.)



**Northumbria
University**
NEWCASTLE



UniversityLibrary

Northumbria Research Link

Underwood, C. P. (2005) 'A fuzzy logic controller for temperature control of air handling plant', CSTB Matlab / Simulink Building and HVAC Simulation Workshop, 3-4 November, SIMBAD.

**CSTB 3rd Matlab/Simulink Building and
HVAC Simulation Workshop
3-4th November 2005, Paris**

**A Fuzzy Logic Controller for
Temperature Control of Air
Handling Plant**

C P Underwood

Northumbria University, United Kingdom




Summary of This Work



- In this work the development of a three-channel fuzzy temperature controller for air handling plant is considered
- Sugeno inference mechanisms are used and their advantages for control type problems are highlighted
- The fuzzy controller is benchmarked against conventionally-tuned PID control
- It is demonstrated that the fuzzy controller is easier to set up than the PID controller whilst offering superior control tracking performance
- The work has made use of Matlab/Simulink as well as the Matlab Fuzzy Logic Toolbox

Background: Fuzzy Inference





Background: Fuzzy Inference Methods

- **Mamdani** inference (the most common method) outputs to fuzzy sets
- Examples (T = temperature)....
- **Sugeno** (or Takagi-Sugeno) inference outputs to numerical values
- Examples (u = valve signal)...

If (T is high) ***Then*** (Valve is low)

If (T is high) ***And*** (dT/dt is negative) ***Then*** (Valve is medium)

Combinatorial rule setting examples:

AND = *min* or *product*
OR = *max* or *probabilistic*


If (T is high) ***Then*** $u = 0$

If (T is low) ***Then*** $u = 1$

If (T is high) ***And*** (dT/dt is negative) ***Then*** $u = 0.5 \cdot \text{input}$


i.e. Sugeno inference can output to some mathematical function of the fuzzy input(s)

Simple Comparison of Inference Methods: Heating Coil Control



Resulting in
sub-saturated
valve
positioning

Can alleviate by
working on the
MFs or use
Sugeno inference




Sugeno case:



If (T is low) Then: Valve = 1

If (T is OK) Then: Valve = Constant*Input

If (T is high) Then: Valve = 0




Results: Alternative Inference Methods (Simple Heating Coil Test Case)




Outlet temperature set point: 10°C

T_{ao} = air outlet temperature T_{ai} = air inlet temperature


The Problem: Sequencing Temperature Control of AHP



Vehicle – Simulink Air Handler Model




PID Control: Ziegler-Nichols Tuning Parameters Fitted to Open Loop Step Response “Tests”




PID tuning parameters:

Loop	K_c	K_i
Damper	-2.620	-3.490
Heating Coil	0.188	0.006
Cooling Coil	-0.108	-0.004


Fuzzy Heating Controller




1. Input MFs



2. Output MFs




3. Rules




4. Surface


Fuzzy Cooling Controller




1. Input MFs



2. Output MFs






3. Rules




4. Surface


Fuzzy Damper Controller



Simulink Model Adapted for Controller Comparisons




Comparative Results: Controlled Variable



Set points: 11°C (heating); 12°C (free cooling); 13°C (cooling) (50% min F/A)

Comparative Results: Signal



CONCLUSIONS



- Fuzzy control over air handling plant temperatures requires no tuning and offers better tracking performance than conventionally-tuned PID control
- Sugeno inference has greater flexibility than conventional Mamdani inference for fuzzy controllers especially at signal saturation and requires no experience/intuition to apply it
- The well known “chatter” around the set point that can arise with fuzzy control has been noted in the present work and needs robust procedures to remove it (conventionally, introducing an additional rate variable can help)